



मुख्य अग्निशमन अधिकारी यांचे कार्यालय,
पुणे महानगरपालिका, पुणे
मध्यवर्ती अग्निशमन केंद्र, महात्मा फुले पेठ,
न्यू टिंबर मार्केटजवळ, पुणे ४११०४२,
टेली नं. ०२०-२६४५०६०१.

Email : pmcfireoffice@punecorporation.org

जावक क्र. अशाद/ ७३८३

दिनांक :- ०४/०५/२०२४

प्रति,

सेवासदन इंग्लिश मिडीयम स्कूल,

एरंडवणे, पुणे-४११००४.

विषय :- पीएस ५५+पीजी २३, स.नं.८+१३/१/१/२, सीटीएस नं.१४१०, एरंडवणे, पुणे येथील शैक्षणिक इमारतीचे ना हरकत दाखल्याच्या नुतनीकरणाबाबत.

संदर्भ :- १) इकडील ना हरकत दाखला जा. क्र.एफ बी /१४६४, दि.१०/०७/२०१७

२) आपलेकडील पत्र इकडील आ.क्र.२९२०, दि.२५/०६/२०२६.

महोदय,

उपरोक्त विषयांकित ठिकाणच्या शैक्षणिक वापराच्या इमारतीकरिता अग्निशामक दलाने संदर्भ क्र. १ अन्वये ना हरकत दाखला देण्यात आलेला होता. इमारतीच्या स्थायी अग्निशमन यंत्रणा सुस्थितीत व कार्यान्वित असलेबाबत मे. डीअनिअर फायर एंटरप्रायझेस प्रा. लि., पुणे यांनी फॉर्म बी सादर केलेला आहे.

तरी उपरोक्त संदर्भ क्र. २ चे पत्रास अनुसरून अग्निशामक दलाने विषयांकित ठिकाणच्या शैक्षणिक वापराच्या इमारतीसाठी संदर्भ क्र. १ अन्वये दिलेल्या ना हरकत दाखल्याचे या पत्राद्वारे नुतनीकरण करण्यात येत असून, सदरील ना हरकत दाखला जानेवारी, जुलै मध्ये फॉर्म बी सादर करण्याच्या अटीवर एक वर्षासाठी ग्राह्य धरण्यात येईल.

मा. स. कळावे.

(राजेश द. जगताप)
स्टेशन ड्युटी ऑफिसर
पुणे महानगरपालिका




LANGUAGE SERVICES BUREAU

Translation, Interpretation & Training in all Foreign & Indian Languages



ISO 9001-2015 Certified

1170, Sadashiv Peth, Off Tilak Road, Shri Shailya
Apartments, 2nd floor, Opp : Shantanu Lodge, Pune -
411030, Maharashtra
Tel: 91-20-24470509 , 91-82370 60559
info@languageservicesbureau.com
www.languageservicesbureau.com



Office of the Chief Fire Officer,
Pune Municipal Corporation, Pune
Center Fire Station, Mahatma Phule Peth,
Near New Timber Market, Pune - 411042.
Tele No. 020-26450601.
Email : pmcfirerooffice@punecorporation.org
Outward. No. FBD/ 1383
Dated.: - **04/07/2025**

To,
Sevasadan English Medium School,
Erandwane, Pune- 411004.

**Subject: - Regarding Renewal of No Objection Certificate of Educational Building at PS 55+
PG 23, S.No. 8+13/1/1/2 CTS NO. 1410 Erandwane, Pune.**

References: - 1) No Objection Certificate of O. No. F B /1464 with us, dated 10/07/2017.
2) Your letter recd here as per I. NO. 2920 dated 25/06/2026.

Dear Sir,

The fire department issued a No Objection Certificate vide reference no. 1 for the use of the building mentioned in the subject above for educational purposes. M/s Disnyr Fire Enterprises Pvt. Ltd., Pune, has submitted Form B mentioning that the installed fire extinguisher system of the building is in good condition.

Therefore, in accordance with the letter mentioned in reference No. 2, the 'No Objection Certificate' is being issued by the Fire Department is being renewed vide this letter for the property mentioned in Reference No. 1 in the subject, for the use of the building above for educational purposes. This No Objection Certificate will be valid for one year on the condition of submitting Form B in January and July.

Thank you.

Sd/-
(Rajesh D. Jagtap)
Station Duty Officer
Pune Municipal Corporation

This is to certify that this is the true and correct English translation of the original document in Marathi. The signed and stamped copy of the original is attached herewith.

For LANGUAGE SERVICES BUREAU
For Language Services Bureau

Madhuri Datar
23/07/2025





Disneyr

Fire Enterprises Pvt.Ltd.

LICENSED FROM

Govt. of Maharashtra
Directorate of Maharashtra
Fire Services

To act as Licensed Agency
for the Purposes of
Fire Prevention & Life Safety
Measures Act, 2006

DFEPL / PSS / 13642 / 25-26

10.06.2025

**THE SECRETARY
PUNE SEVASADAN SOCIETY'S
SEVASADAN ENGLISH MEDIUM SCHOOL,
Erandwane, Pune**

**Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune**

**Wings: " A " : (Gr.+2 Flrs.) &
" B & C " : (B + Gr. + 4 Floors Each)**

Dear Sir/Madam,

Encl. pl. find "B" Certificate.

NOTE :-

**After Maintenance we have Handed Over the Systems with
live Trials & Training to your personnel.**


You / Occupiers are advised to carry out -

- i. Daily checks of Fire Protection Systems & Equipment.**
- ii. Trials Every Month & Report to us for any malfunctioning.**
- iii. Take all reqd. care with initiative to keep the Systems
always in good working condition.**
- iv. Do not neglect System Maintenance.**
- v. Inform us about any Problem in System Operation immediately
which we will attend at extra cost.**

**("B" Certificate is Mandatory in January & July every year
get renewed.)**

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Encl. : a/a



Disnyr

Fire Enterprises Pvt.Ltd.

LICENSED FROM

Govt. of Maharashtra
Directorate of Maharashtra
Fire Services

To act as Licensed Agency
for the Purposes of
Fire Prevention & Life Safety
Measures Act, 2006

FORM B

[See section 3(3) and rule 4(2)]

Six Monthly Certificate for January 2025 for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention &
Life Safety Measures installed in the following Building or Premises, namely :-

PUNE SEVASADAN SOCIETY'S

Site : "SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune

**Wings : " A " : (Gr. + 2 Floors) &
" B & C " : (B + Gr. + 4 Floors Each)**

I / We further certify that these installations in the above mentioned buildings
are maintained in good repair and efficient conditions during the Period

01-Jul-2024 to 31-Dec-2024 as required under the provisions of the -

Maharashtra Fire Prevention and Life Safety Measures Act, 2006

(Mah. III of 2007). The details of the Inspection & Maintenance of installations
carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 10.06.2025

Signature



ROHIT

KULTHE

Digitally signed
by ROHIT KULTHE
Date: 2025.06.10
11:00:30 +05'30'

Copy to:

- ☐ Owner /Occupier of the Bldg./Premises
- ☐ Chief Fire Officer of the Local Authority
- ☐ The Director of Maharashtra Fire Services
- ☐ Office Copy

DISNYR FIRE ENTERPRISES PVT. LTD.

1094, Sadashiv Peth, Raghunath Chambers,
Bajirao Road, Pune - 411 030.

Tel. No. : 24477553/ 24430342 / 7066223388

Email : disnyr.fire@gmail.com/disnyrfireiv@gmail.com

Encl. : Inspection / Compliance Report

INSPECTION / COMPLIANCE REPORT
FOR :- JANUARY 2025

PUNE SEVASADAN SOCIETY'S

Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune
Wings: " A " : (Gr. + 2 Flrs.) &
" B & C " (B + Gr. + 4 Floors Each)

Inspected on: 13.12.2024

Sr.	Equipment	Total Qty.	Remarks
[I]	WET RISER / DOWN COMER SYSTEM :- 3 Nos.		As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Pipeline		
2	Butterfly Valve at Terrace Lvl.	3 Nos.	
3	NRV at Terrace Lvl.	3 Nos.	
4	Booster Pump - 3 HP Cap. with Starter & Cover	3 Nos.	
5	Fire Service Inlet	3 Nos.	
6	Single Outlet Hydt. Valve : ISI Mark	13 Nos.	
7	Hose Box : Single	13 Nos.	Ensured Satisfactory Working of the System.
8	Delivery Hose ISI Marked - 15 Mtrs. with Male / Female Couplings	13 Nos.	
9	Short Branch	13 Nos.	
10	Hose Reel with Shut off nozzle & Rubber Hose	10 Nos.	
11	Fire Extinguishers - ABC Stored Pressure type 4.0 Kg.	36 Nos.	





Fire Enterprises Pvt.Ltd.

Sr.	Equipment	Total Qty.	Remarks
[II]	FIRE ALARM SYSTEM :- 3 Nos.		As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Single Zone Panel	3 Nos.	
2	MCP	13 Nos.	
3	Siren	3 Nos.	Ensured Satisfactory Working of the System.
[III]	SPRINKLER SYSTEM :- in Basement of Wings : " B & C " only		
1	Pipeline		
2	Sprinkler Bulbs	93 Nos. (Approx)	Ensured Satisfactory Working of the System.
3	Pumps	Capacity	
a	Main Pump	20 HP	
b	Jockey Pump	7.5 HP	Ensured Satisfactory Working of the System.
4	Control Panel	1 No.	

NOTE:

**Training in System Operation - Imparted to Security Personnel ,
Staff Members & Occupiers.**

Occupiers advised to carry out -

- Daily checks of Fire Protection Systems & Equipment.**
- Trials Every Month & Report to us for any malfunctioning.**

ROHIT KULTHE Digitally signed by ROHIT KULTHE
Date: 2025.06.10 11:01:28 +05'30'

FOR DISNYR FIRE ENTERPRISES PVT. LTD.





Disneyr

Fire Enterprises Pvt.Ltd.

LICENSED FROM

Govt. of Maharashtra
Directorate of Maharashtra
Fire Services

To act as Licensed Agency
for the Purposes of
Fire Prevention & Life Safety
Measures Act, 2006

DFEPL / PSS / 13704 / 25-26

11.07.2025

**THE SECRETARY
PUNE SEVASADAN SOCIETY'S
SEVASADAN ENGLISH MEDIUM SCHOOL,
Erandwane, Pune**

**Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune**

**Wings: " A " : (Gr.+2 Flrs.) &
" B & C " : (B + Gr. + 4 Floors Each)**

Dear Sir/Madam,

Encl. pl. find "B" Certificate.

NOTE :-

**After Maintenance we have Handed Over the Systems with
live Trials & Training to your personnel.**

You / Occupiers are advised to carry out -

- i. **Daily checks of Fire Protection Systems & Equipment.**
- ii. **Trials Every Month & Report to us for any malfunctioning.**
- iii. **Take all reqd. care with initiative to keep the Systems
always in good working condition.**
- iv. **Do not neglect System Maintenance.**
- v. **Inform us about any Problem in System Operation immediately
which we will attend at extra cost.**

**("B" Certificate is Mandatory in January & July every year
get renewed.)**

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Encl. : a/a



Disnyr

Fire Enterprises Pvt.Ltd.

LICENSED FROM

Govt. of Maharashtra
Directorate of Maharashtra
Fire Services

To act as Licensed Agency
for the Purposes of
Fire Prevention & Life Safety
Measures Act, 2006

FORM B

[See section 3(3) and rule 4(2)]

**Six Monthly Certificate for July 2025
for compliance of the
Fire Prevention and Life Safety Measures.**

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention & Life Safety Measures installed in the following Building or Premises, namely :-

PUNE SEVASADAN SOCIETY'S

**Site : "SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune**

**Wings : " A " : (Gr. + 2 Floors) &
" B & C " : (B + Gr. + 4 Floors Each)**

I / We further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the Period

01-Jan-2025 to 30-Jun-2025 as required under the provisions of the -

Maharashtra Fire Prevention and Life Safety Measures Act, 2006

(Mah. III of 2007). The details of the Inspection & Maintenance of installations carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 11.07.2025

Signature



**ROHIT
KULTHE**

Digitally signed
by ROHIT KULTHE
Date: 2025.07.11
19:13:41 +05'30'

Copy to:

- ☐ Owner /Occupier of the Bldg./Premises
- ☐ Chief Fire Officer of the Local Authority
- ☐ The Director of Maharashtra Fire Services
- ☐ Office Copy

DISNYR FIRE ENTERPRISES PVT. LTD.

1094, Sadashiv Peth, Raghunath Chambers,
Bajirao Road, Pune - 411 030.

Tel. No. : 24477553/ 24430342 / 7066223388

Email : disnyr.fire@gmail.com/disnyrfireiv@gmail.com

Encl. : Inspection / Compliance Report



Fire Enterprises Pvt.Ltd.

INSPECTION / COMPLIANCE REPORT
FOR :- JULY 2025

PUNE SEVASADAN SOCIETY'S

Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune

Wings: " A " : (Gr. + 2 Flrs.) &
" B & C " (B + Gr. + 4 Floors Each)

Inspected on: 10.07.2025

Sr.	Equipment	Total Qty.	Remarks
[I]	WET RISER / DOWN COMER SYSTEM :- 3 Nos.		As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Pipeline		
2	Butterfly Valve at Terrace Lvl.	3 Nos.	
3	NRV at Terrace Lvl.	3 Nos.	
4	Booster Pump - 3 HP Cap. with Starter & Cover	3 Nos.	
5	Fire Service Inlet	3 Nos.	
6	Single Outlet Hydt. Valve : ISI Mark	13 Nos.	
7	Hose Box : Single	13 Nos.	Ensured Satisfactory Working of the System.
8	Delivery Hose ISI Marked - 15 Mtrs. with Male / Female Couplings	13 Nos.	
9	Short Branch	13 Nos.	
10	Hose Reel with Shut off nozzle & Rubber Hose	10 Nos.	
11	Fire Extinguishers - ABC Stored Pressure type 4.0 Kg.	33 Nos.	



Disnyr

Fire Enterprises Pvt.Ltd.

Sr.	Equipment	Total Qty.	Remarks
[II]	FIRE ALARM SYSTEM :- 3 Nos.		As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Single Zone Panel	3 Nos.	
2	MCP	13 Nos.	
3	Siren	3 Nos.	
[III]	SPRINKLER SYSTEM :-		
	in Basement of Wings : " B & C " only		
1	Pipeline		
2	Sprinkler Bulbs	93 Nos. (Approx)	
3	Pumps	Capacity	Ensured Satisfactory Working of the System.
a	Main Pump	20 HP	
b	Jockey Pump	7.5 HP	
4	Control Panel	1 No.	

NOTE:

Training in System Operation - Imparted to Security Personnel , Staff Members & Occupiers.

Occupiers advised to carry out -

- i. **Daily checks of Fire Protection Systems & Equipment.**
- ii. **Trials Every Month & Report to us for any malfunctioning.**

ROHIT KULTHE Digitally signed by ROHIT KULTHE
Date: 2025.07.11 19:14:34 +05'30'

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

