



**LICENSED
FROM**

Govt. of Maharashtra
Directorate of Maharashtra Fire Services | P.M.C.
Fire Dept. |

To act as Licensed Agency for the Purposes of
Fire Prevention & Life Safety Measures Act, 2006

DFEPL / PSS /11193 /20.21

08-Mar-21

**THE SECRETARY
PUNE SEVASADAN SOCIETY'S
SEVASADAN ENGLISH MEDIUM SCHOOL,
Erandwane, Pune**

Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune
Wings: " A " : (1st Floor & 2 Floor only) &
" B & C " : (B + Gr. + 4 Floors Each)

SUB.: ISSUE OF "B" CERTIFICATE

Dear Sir/Madam,

Encl. pl. find "B" Certificate for **January 2021**
for the period : **1-Jan-2021 to 30-June-2021**

NOTE :-

After Maintenance we have Handed Over the Systems with
live Trials & Training to your personnel.

You / Occupiers are advised to carry out -

- i. Daily checks of Fire Protection Systems & Equipment.
- ii. Trials Every Month & Report to us for any malfunctioning.
- iii. Take all reqd. care with initiative to keep the Systems
always in good working condition.
- iv. Do not neglect System Maintenance.
- v. Inform us about any Problem in System Operation immediately
which we will attend at extra cost.

("B" Certificate is Mandatory in January & July every year).


FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Encl. : a/a

CORPORATE OFFICE :

1094, Sadashiv Peth, Raghunath Chambers, Opp. Janata Sahakari Bank Ltd., Bajirao Road, Pune - 411030.
Tel: (020) 2447 7553 / 2443 0342. Email : disnyr.fire@gmail.com / disnyrfireiv@gmail.com
Website : www.dfsnyrfire.com

REGD. OFFICE :

1070, Sadashiv Peth, Ramdoot Society,
Pune - 411030.





**LICENSED
FROM**

Govt. of Maharashtra
Directorate of Maharashtra Fire Services

PMC
Fire Dept.

To act as Licensed Agency for the Purposes of
Fire Prevention & Life Safety Measures Act, 2006

FORM B

[See section 3(3) and rule 4(2)]

**Six Monthly Certificate for January 2021
for compliance of the
Fire Prevention and Life Safety Measures.**

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention &
Life Safety Measures installed in the following Building or Premises, namely :-

PUNE SEVASADAN SOCIETY'S
Site : "SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune

Wings : " A " : (1st Floor & 2 Floor only) &
" B & C " : (B + Gr. + 4 Floors Each)

I / We further certify that these installations in the above mentioned buildings
are maintained in good repair and efficient conditions during the Period
1-Jan-2021 to 30-June-2021 as required under the provisions of the -
Maharashtra Fire Prevention and Life Safety Measures Act, 2006
(Mah. III of 2007), The details of the Inspection & Maintenance of Installations
carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 08-March-2021

Signature

Neelkanth V. Datar
Disnyr Fire Ent. Pvt. Ltd.
Licensed Agency
PMC Fire Dept.
Licence No. : PMC/FIRE/LA-01
Dt.: 31.03.2011

Copy to:

- Owner /Occupier of the Bldg./Premises
 Chief Fire Officer of the Local Authority
 The Director of Maharashtra Fire Services
 Office Copy

DISNYR FIRE ENTERPRISES PVT. LTD.

1094, Sadashiv Peth, Raghunath Chambers,
Bajirao Road, Pune - 411 030.

Tel. No. : 24477553/ 24430342, Fax: 24477545

Email : disnyr.fire@gmail.com
disnyrfireiv@gmail.com

✓ Encl. : Inspection / Compliance Report



CORPORATE OFFICE :

1094, Sadashiv Peth, Raghunath Chambers, Opp. Janata Sahakar Bank Ltd., Bajirao Road, Pune - 411030.
Tel.: (020) 2447 7553 / 2443 0342. Email : disnyr.fire@gmail.com / disnyrfireiv@gmail.com
Website : www.disnyrfire.com

REGD. OFFICE :

1070, Sadashiv Peth, Ramdas Society,
Pune - 411030.



INSPECTION / COMPLIANCE REPORT
FOR :- JANUARY 2021

PUNE SEVASADAN SOCIETY'S

Site : " SEVASADAN ENGLISH MEDIUM SCHOOL",
Erandwane, Pune

Wings: " A " : (1st Floor & 2 Floor only) &
" B & C " (B + Gr. + 4 Floors Each)

Inspected on: 08-Mar-21

Sr.	Equipment	Total Qty.	Remarks
[I]	WET RISER / DOWN COMER SYSTEM :- 3 Nos.		As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Pipeline		
2	Valve at Terrace Lvl.	3 Nos.	
3	NRV at Terrace Lvl.	3 Nos.	
4	Booster Pump - 3 HP Cap. with Starter & Cover	3 Nos.	
5	Fire Service Inlet	3 Nos.	
6	Single Outlet Hydt. Valve : ISI Mark	13 Nos.	
7	Hose Box : Single	13 Nos.	
8	Delivery Hose ISI Marked - 15 Mtrs. with Male / Female Couplings	13 Nos.	Ensured Satisfactory Working of the System.
9	Short Branch	13 Nos.	
10	Hose Reel with Shut off nozzle & Rubber Hose	10 Nos.	
11	Fire Extinguishers - ABC Stored Pressure type 4.0 Kg.	24 Nos.	





[II]	FIRE ALARM SYSTEM :- 3 Nos.			As per our Survey Report - Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Single Zone Panel		3 Nos.	
2	MCP		13 Nos.	
3	Siren		3 Nos.	
[III]	SPRINKLER SYSTEM :- in Basement of Wings : " B & C " only			Ensured Satisfactory Working of the System.
1	Pipeline			
2	Sprinkler Bulbs		93 Nos. (Approx)	
3	Pumps	Capacity		
a	Main Pump	20 HP	1 No.	
b	Jockey Pump	7.5 HP	1 No.	
4	Control Panel		1 No.	

NOTE:

Training in System Operation -

Imparted to Security Personnel ,
Staff Members & Occupiers.

Occupiers advised to carry out -

- i. Daily checks of Fire Protection Systems & Equipment.
- ii. Trials Every Month & Report to us for any malfunctioning.

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Sevasadan English Medium School

Manager

Headmistress

Principal